SIEMENS

## Data sheet 6AG1510-1DJ01-2AB0



Figure similar

SIPLUS ET 200SP CPU 1510SP-1 PN based on 6ES7510-1DJ01-0AB0 with conformal coating, -40…+60 °C, central processing unit with work memory 100 KB for program and 750 KB for data, 1st interface, PROFINET IRT with 3-port switch, 72 ns bit performance, SIMATIC Memory Card required, BusAdapter required for port 1 and 2

| | |
|---|---|
| **General information** | |
| Product type designation | CPU 1510SP-1 PN |
| based on | 6ES7510-1DJ01-0AB0 |
| Product function | |
| ● I&M data | Yes; I&M0 to I&M3 |
| ● Module swapping during operation (hot swapping) | Yes; Multi-hot swapping |
| ● Isochronous mode | Yes; Only with PROFINET; with minimum OB 6x cycle of 625 µs |
| Engineering with | |
| ● STEP 7 TIA Portal configurable/integrated from version | see entry ID: 109746275 |
| **Configuration control** | |
| via dataset | Yes |
| **Control elements** | |
| Mode selector switch | 1 |
| **Supply voltage** | |
| Rated value (DC) | 24 V |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |
| Reverse polarity protection | Yes |
| Mains buffering | |
| ● Mains/voltage failure stored energy time | 5 ms |
| **Input current** | |
| Current consumption (rated value) | 0.6 A |
| Current consumption, max. | 0.9 A |
| Inrush current, max. | 4.7 A; Rated value |
| $I^2t$ | 0.14 $A^2 \cdot s$ |
| **Power** | |
| Infeed power to the backplane bus | 8.75 W |
| **Power loss** | |
| Power loss, typ. | 5.6 W |
| **Storage** | |
| Number of slots for SIMATIC memory card | 1 |
| SIMATIC memory card required | Yes |
| Work memory | |
| ● integrated (for program) | 100 kbyte |
| ● integrated (for data) | 750 kbyte |
| Load memory | |
| ● Plug-in (SIMATIC Memory Card), max. | 32 Gbyte |
| Backup | |


© Copyright Plcbin

| | |
|---|---|
| ● maintenance-free | Yes |
| **CPU processing times** | |
| for bit operations, typ. | 72 ns |
| for word operations, typ. | 86 ns |
| for fixed point arithmetic, typ. | 115 ns |
| for floating point arithmetic, typ. | 461 ns |
| **CPU-blocks** | |
| Number of elements (total) | 4 000; Blocks (OB, FB, FC, DB) and UDTs |
| DB | |
| ● Number range | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| ● Size, max. | 750 kbyte; For DBs with absolute addressing, the max. size is 64 KB |
| FB | |
| ● Number range | 0 ... 65 535 |
| ● Size, max. | 100 kbyte |
| FC | |
| ● Number range | 0 ... 65 535 |
| ● Size, max. | 100 kbyte |
| OB | |
| ● Size, max. | 100 kbyte |
| ● Number of free cycle OBs | 100 |
| ● Number of time alarm OBs | 20 |
| ● Number of delay alarm OBs | 20 |
| ● Number of cyclic interrupt OBs | 20; With minimum OB 3x cycle of 500 µs |
| ● Number of process alarm OBs | 50 |
| ● Number of DPV1 alarm OBs | 3 |
| ● Number of isochronous mode OBs | 1 |
| ● Number of technology synchronous alarm OBs | 2 |
| ● Number of startup OBs | 100 |
| ● Number of asynchronous error OBs | 4 |
| ● Number of synchronous error OBs | 2 |
| ● Number of diagnostic alarm OBs | 1 |
| Nesting depth | |
| ● per priority class | 24 |
| **Counters, timers and their retentivity** | |
| S7 counter | |
| ● Number | 2 048 |
| Retentivity | |
| — can be set | Yes |
| IEC counter | |
| ● Number | Any (only limited by the main memory) |
| Retentivity | |
| — can be set | Yes |
| S7 timer | |
| ● Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC timer | |
| ● Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| **Data areas and their retentivity** | |
| Retentive data area (incl. timers, counters, flags), max. | 128 kbyte; Available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB |
| Flag | |
| ● Size, max. | 16 kbyte |
| ● Number of clock memories | 8; 8 clock memory bit, grouped into one clock memory byte |
| Data blocks | |
| ● Retentivity adjustable | Yes |


© Copyright Plcbin

| | |
|---|---|
| ● Retentivity preset | No |
| Local data | |
| ● per priority class, max. | 64 kbyte; max. 16 KB per block |
| **Address area** | |
| Number of IO modules | 1 024; max. number of modules / submodules |
| I/O address area | |
| ● Inputs | 32 kbyte; All inputs are in the process image |
| ● Outputs | 32 kbyte; All outputs are in the process image |
| per integrated IO subsystem | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| per CM/CP | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| Subprocess images | |
| ● Number of subprocess images, max. | 32 |
| Address space per module | |
| ● Address space per module, max. | 288 byte; For input and output data respectively |
| Address space per station | |
| ● Address space per station, max. | 2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules |
| **Hardware configuration** | |
| Number of distributed IO systems | 32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters | |
| ● Via CM | 1 |
| Number of IO Controllers | |
| ● Integrated | 1 |
| ● via CM | 0 |
| Rack | |
| ● Modules per rack, max. | 80; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules |
| ● Quantity of operable ET 200SP modules, max. | 64 |
| ● Quantity of operable ET 200AL modules, max. | 16 |
| ● Number of lines, max. | 1 |
| PtP CM | |
| ● Number of PtP CMs | the number of connectable PtP CMs is only limited by the number of available slots |
| **Time of day** | |
| Clock | |
| ● Type | Hardware clock |
| ● Backup time | 6 wk; At 40 °C ambient temperature, typically |
| ● Deviation per day, max. | 10 s; Typ.: 2 s |
| Operating hours counter | |
| ● Number | 16 |
| Clock synchronization | |
| ● supported | Yes |
| ● to DP, master | Yes; Via CM DP module |
| ● on DP, device | Yes; Via CM DP module |
| ● in AS, master | Yes |
| ● in AS, device | Yes |
| ● on Ethernet via NTP | Yes |
| **Interfaces** | |
| Number of PROFINET interfaces | 1 |
| Number of PROFIBUS interfaces | 1; Via CM DP module |
| Optical interface | No |
| **1. Interface** | |
| Interface types | |
| ● RJ 45 (Ethernet) | Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45 |


© Copyright Plcbin

| | |
|---|---|
| ● Number of ports | 3; 1. integr. + 2. via BusAdapter |
| ● integrated switch | Yes |
| ● BusAdapter (PROFINET) | Yes; compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x M12 |
| Protocols | |
| ● IP protocol | Yes; IPv4 |
| ● PROFINET IO Controller | Yes |
| ● PROFINET IO device | Yes |
| ● SIMATIC communication | Yes |
| ● Open IE communication | Yes; Optionally also encrypted |
| ● Web server | Yes |
| ● Media redundancy | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0 |
| PROFINET IO Controller | |
| Services | |
| — PG/OP communication | Yes |
| — Isochronous mode | Yes |
| — Direct data exchange | Yes; Requirement: IRT and isochronous mode (MRPD optional) |
| — IRT | Yes |
| — PROFIenergy | Yes; per user program |
| — Prioritized startup | Yes; Max. 32 PROFINET devices |
| — Number of connectable IO Devices, max. | 64; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| — Of which IO devices with IRT, max. | 64 |
| — Number of connectable IO Devices for RT, max. | 64 |
| — of which in line, max. | 64 |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces |
| — Number of IO Devices per tool, max. | 8 |
| — Updating times | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| Update time for IRT | |
| — for send cycle of 250 µs | 250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 µs of the isochronous OB is decisive |
| — for send cycle of 500 µs | 500 µs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 µs of the isochronous OB is decisive |
| — for send cycle of 1 ms | 1 ms to 16 ms |
| — for send cycle of 2 ms | 2 ms to 32 ms |
| — for send cycle of 4 ms | 4 ms to 64 ms |
| — With IRT and parameterization of "odd" send cycles | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs) |
| Update time for RT | |
| — for send cycle of 250 µs | 250 µs to 128 ms |
| — for send cycle of 500 µs | 500 µs to 256 ms |
| — for send cycle of 1 ms | 1 ms to 512 ms |
| — for send cycle of 2 ms | 2 ms to 512 ms |
| — for send cycle of 4 ms | 4 ms to 512 ms |
| PROFINET IO Device | |
| Services | |
| — PG/OP communication | Yes |
| — Isochronous mode | No |
| — IRT | Yes |
| — PROFIenergy | Yes; per user program |
| — Shared device | Yes |
| — Number of IO Controllers with shared device, max. | 4 |
| — activation/deactivation of I-devices | Yes; per user program |
| — Asset management record | Yes; per user program |
| **2. Interface** | |
| Interface types | |
| ● RS 485 | Yes; Via CM DP module |
| ● Number of ports | 1 |
| Protocols | |


© Copyright Plcbin

| | |
|---|---|
| ● PROFIBUS DP master | Yes |
| ● PROFIBUS DP device | Yes |
| ● SIMATIC communication | Yes |
| PROFIBUS DP master | |
| ● Number of connections, max. | 48; Of which 4 each reserved for ES and HMI |
| ● max. number of DP devices | 125; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| Services | |
| — PG/OP communication | Yes |
| — Equidistance | No |
| — Isochronous mode | No |
| — activation/deactivation of DP devices | Yes |
| **Interface types** | |
| RJ 45 (Ethernet) | |
| ● 100 Mbps | Yes |
| ● Autonegotiation | Yes |
| ● Autocrossing | Yes |
| ● Industrial Ethernet status LED | Yes |
| RS 485 | |
| ● Transmission rate, max. | 12 Mbit/s |
| **Protocols** | |
| PROFIsafe | No |
| Number of connections | |
| ● Number of connections, max. | 96; via integrated interfaces of the CPU and connected CPs / CMs |
| ● Number of connections reserved for ES/HMI/web | 10 |
| ● Number of connections via integrated interfaces | 64 |
| ● Number of connections per CP/CM | 32 |
| ● Number of S7 routing paths | 16 |
| Redundancy mode | |
| ● H-Sync forwarding | Yes |
| Media redundancy | |
| — Media redundancy | Yes; only via BusAdapter |
| — MRP | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client |
| — MRP interconnection, supported | Yes; as MRP ring node according to IEC 62439-2 Edition 3.0 |
| — MRPD | Yes; Requirement: IRT |
| — Switchover time on line break, typ. | 200 ms; For MRP, bumpless for MRPD |
| — Number of stations in the ring, max. | 50 |
| SIMATIC communication | |
| ● PG/OP communication | Yes; encryption with TLS V1.3 pre-selected |
| ● S7 routing | Yes |
| ● Data record routing | Yes |
| ● S7 communication, as server | Yes |
| ● S7 communication, as client | Yes |
| ● User data per job, max. | See online help (S7 communication, user data size) |
| Open IE communication | |
| ● TCP/IP | Yes |
| — Data length, max. | 64 kbyte |
| — several passive connections per port, supported | Yes |
| ● ISO-on-TCP (RFC1006) | Yes |
| — Data length, max. | 64 kbyte |
| ● UDP | Yes |
| — Data length, max. | 2 kbyte; 1 472 bytes for UDP broadcast |
| — UDP multicast | Yes; Max. 5 multicast circuits |
| ● DHCP | Yes |
| ● DNS | Yes |
| ● SNMP | Yes |
| ● DCP | Yes |
| ● LLDP | Yes |


© Copyright Plcbin

| | |
|---|---|
| ● encryption | Yes; Optional |
| Web server | |
| ● HTTP | Yes; Standard and user pages |
| ● HTTPS | Yes; Standard and user pages |
| OPC UA | |
| ● Runtime license required | Yes; "Small" license required |
| ● OPC UA Client | Yes |
| — Application authentication | Yes |
| — Security policies | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication | "anonymous" or by user name & password |
| — Number of connections, max. | 4 |
| — Number of nodes of the client interfaces, recommended max. | 1 000 |
| — Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_U max. | 300 |
| — Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. | 20 |
| — Number of elements for one call of OPC_UA_MethodGetHandleList, max. | 100 |
| — Number of simultaneous calls of the client instructions for session management, per connection, max. | 1 |
| — Number of simultaneous calls of the client instructions for data access, per connection, max. | 5 |
| — Number of registerable nodes, max. | 5 000 |
| — Number of registerable method calls of OPC_UA_MethodCall, max. | 100 |
| — Number of inputs/outputs when calling OPC_UA_MethodCall, max. | 20 |
| ● OPC UA Server | Yes; Data access (read, write, subscribe), method call, custom address space |
| — Application authentication | Yes |
| — Security policies | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication | "anonymous" or by user name & password |
| — GDS support (certificate management) | Yes |
| — Number of sessions, max. | 32 |
| — Number of accessible variables, max. | 50 000 |
| — Number of registerable nodes, max. | 10 000 |
| — Number of subscriptions per session, max. | 20 |
| — Sampling interval, min. | 100 ms |
| — Publishing interval, min. | 500 ms |
| — Number of server methods, max. | 20 |
| — Number of inputs/outputs per server method, max. | 20 |
| — Number of monitored items, recommended max. | 1 000; for 1 s sampling interval and 1 s send interval |
| — Number of server interfaces, max. | 10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace" |
| — Number of nodes for user-defined server interfaces, max. | 1 000 |
| ● Alarms and Conditions | Yes |
| — Number of program alarms | 100 |
| — Number of alarms for system diagnostics | 50 |
| Further protocols | |
| ● MODBUS | Yes; MODBUS TCP |
| **S7 message functions** | |
| Number of login stations for message functions, max. | 32 |
| Program alarms | Yes |
| Number of configurable program messages, max. | 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH |
| Number of loadable program messages in RUN, max. | 2 500 |
| Number of simultaneously active program alarms | |
| ● Number of program alarms | 600 |


© Copyright Plcbin

| | |
|---|---|
| ● Number of alarms for system diagnostics | 100 |
| ● Number of alarms for motion technology objects | 80 |
| **Test commissioning functions** | |
| Joint commission (Team Engineering) | Yes; Parallel online access possible for up to 5 engineering systems |
| Status block | Yes; Up to 8 simultaneously (in total across all ES clients) |
| Single step | No |
| Number of breakpoints | 8 |
| Status/control | |
| ● Status/control variable | Yes |
| ● Variables | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters |
| ● Number of variables, max. | |
| — of which status variables, max. | 200; per job |
| — of which control variables, max. | 200; per job |
| Forcing | |
| ● Forcing | Yes |
| ● Forcing, variables | Peripheral inputs/outputs |
| ● Number of variables, max. | 200 |
| Diagnostic buffer | |
| ● present | Yes |
| ● Number of entries, max. | 1 000 |
| — of which powerfail-proof | 500 |
| Traces | |
| ● Number of configurable Traces | 4; Up to 512 KB of data per trace are possible |
| **Interrupts/diagnostics/status information** | |
| Diagnostics indication LED | |
| ● RUN/STOP LED | Yes |
| ● ERROR LED | Yes |
| ● MAINT LED | Yes |
| ● Monitoring of the supply voltage (PWR-LED) | Yes |
| ● Connection display LINK TX/RX | Yes |
| **Supported technology objects** | |
| Motion Control | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool |
| ● Number of available Motion Control resources for technology objects | 800 |
| ● Required Motion Control resources | |
| — per speed-controlled axis | 40 |
| — per positioning axis | 80 |
| — per synchronous axis | 160 |
| — per external encoder | 80 |
| — per output cam | 20 |
| — per cam track | 160 |
| — per probe | 40 |
| ● Positioning axis | |
| — Number of positioning axes at motion control cycle of 4 ms (typical value) | 5 |
| — Number of positioning axes at motion control cycle of 8 ms (typical value) | 10 |
| Controller | |
| ● PID_Compact | Yes; Universal PID controller with integrated optimization |
| ● PID_3Step | Yes; PID controller with integrated optimization for valves |
| ● PID-Temp | Yes; PID controller with integrated optimization for temperature |
| Counting and measuring | |
| ● High-speed counter | Yes |
| **Ambient conditions** | |
| Ambient temperature during operation | |
| ● horizontal installation, min. | -40 °C; = Tmin (incl. condensation/frost) |
| ● horizontal installation, max. | 60 °C; = Tmax |
| ● vertical installation, min. | -25 °C; = Tmin |
| ● vertical installation, max. | 50 °C; = Tmax |


© Copyright Plcbin

| | |
|---|---|
| Altitude during operation relating to sea level | |
| ● Installation altitude above sea level, max. | 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual |
| Relative humidity | |
| ● With condensation, tested in accordance with IEC 60068-2-38, max. | 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation |
| Resistance | |
| Coolants and lubricants | |
| — Resistant to commercially available coolants and lubricants | Yes; Incl. diesel and oil droplets in the air |
| Use in stationary industrial systems | |
| — to biologically active substances according to EN 60721-3-3 | Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request |
| — to chemically active substances according to EN 60721-3-3 | Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); * |
| — to mechanically active substances according to EN 60721-3-3 | Yes; Class 3S4 incl. sand, dust, * |
| — Against mechanical environmental conditions acc. to EN 60721-3-3 | Yes; Class 3M8 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0) |
| Use on land craft, rail vehicles and special-purpose vehicles | |
| — Against mechanical environmental conditions acc. to EN 60721-3-5 | Yes; Class 5M2 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0) |
| — against mechanical environmental conditions in agriculture acc. to ISO 15003 | Yes; level 1 (Location LE) using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0) |
| Use on ships/at sea | |
| — to biologically active substances according to EN 60721-3-6 | Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna) |
| — to chemically active substances according to EN 60721-3-6 | Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); * |
| — to mechanically active substances according to EN 60721-3-6 | Yes; Class 6S3 incl. sand, dust; * |
| — Against mechanical environmental conditions acc. to EN 60721-3-6 | Yes; Class 6M4 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0) |
| Usage in industrial process technology | |
| — Against chemically active substances acc. to EN 60654-4 | Yes; Class 3 (excluding trichlorethylene) |
| — Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04 | Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil) |
| Remark | |
| — Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 | * The supplied plug covers must remain in place over the unused interfaces during operation! |
| Conformal coating | |
| ● Coatings for printed circuit board assemblies acc. to EN 61086 | Yes; Class 2 for high reliability |
| ● Protection against fouling acc. to EN 60664-3 | Yes; Type 1 protection |
| ● Military testing according to MIL-I-46058C, Amendment 7 | Yes; Discoloration of coating possible during service life |
| ● Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A | Yes; Conformal coating, Class A |
| **Configuration** | |
| Programming | |
| Programming language | |
| — LAD | Yes |
| — FBD | Yes |
| — STL | Yes |
| — SCL | Yes |
| — GRAPH | Yes |
| Know-how protection | |
| ● User program protection/password protection | Yes |
| ● Copy protection | Yes |
| ● Block protection | Yes |
| Access protection | |
| ● protection of confidential configuration data | Yes |
| ● Protection level: Write protection | Yes |


© Copyright Plcbin

| | |
|---|---|
| ● Protection level: Read/write protection | Yes |
| ● Protection level: Complete protection | Yes |
| Cycle time monitoring | |
| ● lower limit | adjustable minimum cycle time |
| ● upper limit | adjustable maximum cycle time |

**Dimensions**

| | |
|---|---|
| Width | 100 mm |
| Height | 117 mm |
| Depth | 75 mm |

**Weights**

| | |
|---|---|
| Weight, approx. | 310 g |

**Classifications**

| | Version | Classification |
|---|---|---|
| eClass | 16 | 27-24-26-07 |
| eClass | 14 | 27-24-26-07 |
| eClass | 12 | 27-24-26-07 |
| eClass | 9.1 | 27-24-26-07 |
| eClass | 9 | 27-24-26-07 |
| eClass | 8 | 27-24-26-07 |
| eClass | 7.1 | 27-24-26-07 |
| eClass | 6 | 27-24-26-07 |
| ETIM | 10 | EC001603 |
| ETIM | 9 | EC001603 |
| ETIM | 8 | EC001603 |
| ETIM | 7 | EC001603 |
| IDEA | 4 | 3565 |
| UNSPSC | 15 | 32-15-17-05 |

**Approvals / Certificates**

**General Product Approval**

Manufacturer Declaration

China RoHS

| General Product Approval | EMV | For use in hazardous locations | | | Maritime application |
|---|---|---|---|---|---|
| China RoHS | | CCC-Ex | | | |

**last modified:** 12/8/2024


© Copyright Plcbin